

USAID Global Health Supply Chain Program
Procurement and Supply Management

RFP-ZMB-FIRESYSTEM-2019

SUPPLY, DELIVERY AND INSTALLATION OF STORAGE SYSTEMS, CONVEYOR SYSTEMS, FENCING AND GATES, PICK TROLLEYS, DOCK LEVELLERS, HVAC SYSTEMS AND FIRE PROTECTION SYSTEMS FOR THE MEDICAL STORES WAREHOUSE IN LUANSHYA DISTRICT IN ZAMBIA

Addendum #1

Date of Issue: April 29, 2019

The purpose of this addendum is to extend the deadline for proposals to May 7, update the scope of work and attachments, and respond to all questions submitted as of April 23, 2019. Offerors shall note that the deadline to submit questions has passed and Chemonics International will not respond to questions submitted after the April 23, 2019 deadline.

Additionally, all offerors shall note that Chemonics International will be the sole contracting party to any resulting subcontract. Bidders must rely only on written guidance from Chemonics International in preparing their proposals and should not rely on any promises or speculation from a third party.

Any inquiries regarding this correspondence should be addressed to PSMZambiaProcurement@gmail.com. No phone calls will be accepted and all questions must be in writing. Thank you for your continued interest in GHSC-PSM Zambia.

ANSWERS IN RESPONSE TO QUESTIONS SUBMITTED AS OF APRIL 23, 2019:

Question No.	RFP Reference	Details
1	1.6 Technical Volume, page 6	<p>The tender requires “Copy of official license of legal registration in Zambia”. Is this tender restricted to Zambian companies? Or can offerors submit registration documents from other countries?</p> <p>This tender is not restricted to Zambian companies, but offerors must submit documentation that they are legally authorized to operate in Zambia.</p>
2	2.A.1 Scope of Work, page 18	<p>Please confirm the number of personnel to be trained or the approximate number.</p> <p>Approximately 10 people will need to be trained.</p>
3	Attachment 18. Taxes and Duties, page 28	<p>Please inform us who shall be responsible for processing of the tax exemption documents in order to allow for the tax free import of the equipment.</p> <p>Chemonics International shall assist with any tax exemption documentation required.</p>

EXTENSION OF PROPOSAL DEADLINE AND UPDATES TO SCOPE OF WORK AND ATTACHMENTS:

Item No.	RFP Reference	Details
1	1.2 Offer Deadline	Delete first sentence and insert the following in its place: Offers must be received in hard and soft copy no later than 17.00 hrs local Zambia time on 7 th May 2019 at the following address.
2	2.A Scope of Work, page 13	Add to “Ongoing MSL Operations” paragraph: Offerors shall note that MSL will allow subcontract activities during weekend and evening hours.
3	2.A Scope of Work, page 14	Delete item 7 Alarm in its entirety and replace with: 7. Smoke Alarm: Proposals shall include audible smoke alarms in the central store room, valve manifold enclosure and pump house. Specifications and sensor unit layout details shall be included in the Technical Volume. Height of sensor units above the floor must be accessible to MSL maintenance personnel using existing MSL equipment.
4	2.A Scope of Work, page 15	Add to Item 5: All pipe penetrations through the existing warehouse walls shall include sleeves. Details shall be provided in the Technical Volume.
5	2.A.1 Scope of Work, page 19	Deliverable 4: Delete “valves and alarm/control/monitoring panels” and insert “valves and pumphouse/manifold enclosure alarm/control/monitoring panels”
6	Attachment G, Section G.2 Fire Detection, page 76	Delete Section G.2 in its entirety. Offerors are referred to smoke alarms provisions in Section 2.A Scope of Work, new item 7 on page 14.